

CERTIFICATE

№ LVD- 08 - 000 - (2-09-816)- 151

"CTEC" Ltd. verifies that

Product

Tower Mounted Switchgear, SCA - plastic

Trade mark: **ELMARK**; type: **MTT-630**, iden. №: **EH001-7/2009**
rated voltage 230/400 V, 50 Hz; rated current 630 A; IP 44

Applicant

"ELMARK HOLDING " S.C.,
ZPZ 10" Perla" str., Varna, Bulgaria
tel.: +359 52 575 500

Manufacturer

"ELMARK INDUSTRIES" S.C.,
2 "Dodrudja" blvd., Dobrich, Bulgaria
tel.: +359 58 500 059

**Comply with the
requirements of:**

BDS EN 60439-1:2002 Low-voltage switchgear and controlgear assemblies Part 1: Type-tested and partially type-tested assemblies - cl.3, cl.4, cl.5, cl.6, cl.7.1, cl.7.2, cl.7.3, cl.7.4, cl.7.6, cl.7.7, cl.7.8, cl.7.9, cl.7.10, cl.7.11

BDS EN 60439-1:2002/A1:2006 Low-voltage switchgear and controlgear assemblies Part 1: Type-tested and partially type-tested assemblies.

BDS EN 60439-5:2002 Low-voltage switchgear and controlgear assemblies Part 5: Particular requirements for assemblies intended to be installed outdoors in public places - Cable distribution cabinets (CDCs) for power distribution in networks- cl.3, cl.4, cl.5, cl.6, cl.7.1, cl.7.2, cl.7.4, cl.7.6

**Certificate has been
issued on the base of
test reports:**

Test report:
№ 2-09-816/17.06.2009

Date of issuing: 21st July 2009
Stara Zagora



Manager CTEC Ltd.
Dipl. eng. Blagovesta Shineva/

