

# CERTIFICATE

№ LVD- 08 - 000 - (2-09-812)- 150

"CTEC" Ltd. verifies that

**Product**

**Low Voltage Main Switchboard**, SCA- metallic  
Trade mark: **ELMARK**; type: **GRT-630**, iden. №: **EH001-6/2009**  
rated voltage 230/400 V, 50 Hz; rated current 630 A; IP 65

**Applicant**

**"ELMARK HOLDING" S.C.**,  
ZPZ 10" Perla" str., Varna, Bulgaria  
tel.: +359 52 575 500

**Manufacturer**

**"ELMARK INDUSTRIES" S.C.**,  
2 "Dodrudja" blvd., Dobrich, Bulgaria;  
tel. +35958/500 059

**Comply with the requirements of:**



**BDS EN 60439-1:2002** Low-voltage switchgear and controlgear assemblies Part 1: Type-tested and partially type-tested assemblies - cl.3, cl.4, cl.5, cl.6, cl.7.1, cl.7.2, cl.7.3, cl.7.4, cl.7.6, cl.7.7, cl.7.8, cl.7.9, cl.7.10, cl.7.11

**BDS EN 60439-1:2002/A1:2006** Low-voltage switchgear and controlgear assemblies Part 1: Type-tested and partially type-tested assemblies.

**Certificate has been issued on the base of test reports:**

Test report:  
№ **2-09-812/16.06.2009**

Date of issuing: 21<sup>st</sup> July 2009  
Stara Zagora



Manager CTEC Ltd.  
dipl. eng. Blagovesta Shineva/